

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

The following services have been tested/approved in accordance with:

AS1530.4:2014 & AS4072.1:2005

protecting penetrations through 60min fire rated lightweight partitions.

**Service penetrations in a minimum 90mm thick wall using minimum 64mm steel stud clad with minimum 13mm Fire Rated Plasterboard each face**

Service	Protection	FRL	Approval No
40-100mm uPVC pipe	PROMASTOP® UniCollar®	-/60/60	Holmes 148209
150mm uPVC pipe	PROMASTOP® UniCollar® (+13mm thickening to both faces)	-/60/60	Holmes 148209
40mm HDPE pipe	PROMASTOP® UniCollar®	-/60/60	Holmes 148042
100mm HDPE pipe	PROMASTOP® UniCollar® (+13mm thickening to both faces)	-/60/60	A-24-009
16-20mm PE/AL/PEX pipe	PROMASEAL® CFC32	-/60/60	FAS220123
20-32mm PEX pipe	PROMASEAL® CFC32	-/60/60	FAS220123
P20 Telstra uPVC electrical conduit 50% filled with fibre optic cables (12 cores, 3 mode)	PROMASEAL® CFC32	-/60/60	FAS220123
P20 Telstra uPVC electrical conduit with fibre 2 x 2.5mm 2C+E TPS Cable	PROMASEAL® CFC32	-/60/60	FAS220123
18 & 28mm PB Pipe	PROMASEAL® CFC32	-/60/60	Holmes 148039
16mm PEX pipe	PROMASEAL® AG Intumescent Sealant	-/60/60	A-17-039
20mm PEX pipe	PROMASEAL® AG Intumescent Sealant	-/60/60	A-17-034A
15-100mm Nitrile Rubber (Armaflex etc) lagged copper pipes	PROMASEAL® FlexiWrap	-/60/60	Holmes 148040
15-100mm Copper Pipes	PROMASEAL® A Acrylic Sealant + 300mm long PROMASEAL® SupaWrap to both faces	-/60/60	Holmes 148040 & 148041
6.35mm/12.70mm pair coil set	PROMASEAL® AG Intumescent Sealant	-/60/60	A-17-034A
32mm FLEXONE Steel Pipe	PROMASEAL® A Acrylic Sealant	-/60/60	A-18-041
D1 Cable Set (Electrical)	PROMASEAL® A Acrylic Sealant + 300mm long PROMASEAL® SupaWrap to both faces	-/60/60	Holmes 148041
D2 Cable Set (Comms)	PROMASEAL® A Acrylic Sealant + 300mm long PROMASEAL® SupaWrap to both faces	-/60/60	Holmes 148041
Data Cables x 6	PROMASEAL® A Acrylic Sealant	-/60/60	Holmes 148039

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

The following services have been tested/approved in accordance with:

AS1530.4:2014 & AS4072.1:2005

protecting penetrations through 60min fire rated lightweight partitions.

**Service penetrations in a minimum 90mm thick wall using minimum 64mm steel stud clad with minimum 13mm Fire Rated Plasterboard each face**

Service	Protection	FRL	Approval No
7/8 Corrugated Co-ax Cable	PROMASEAL® A Acrylic Sealant + 300mm long PROMASEAL® SupaWrap to both faces	-/60/60	Holmes 148039
3 x 35mm <sup>2</sup> Aluminum Core Cables	PROMASEAL® A Acrylic Sealant + 300mm long PROMASEAL® SupaWrap to both faces	-/60/60	Holmes 148039
5 x Fibre Optic Cables	PROMASEAL® A Acrylic Sealant	-/60/60	Holmes 148041
1 x 16mm <sup>2</sup> Electrical Cable	PROMASEAL® A Acrylic Sealant	-/60/60	A-24-009
Up to 5 x 2.5mm 2C+E TPS Cable	PROMASEAL® A Acrylic Sealant	-/60/60	Holmes 148039
Up to 1200(W)x600(H)mm Blank Opening	Single Layer of PROMASEAL® Bulkhead Batt	-/60/60	FAS190202 R4.4
50-100mm uPVC	Single Layer of PROMASEAL® Bulkhead Batt + PROMASEAL® FC	-/60/60	FAS190202 R4.4
Single or up to 25mm bundle of TPS Cables	Single Layer of PROMASEAL® Bulkhead Batt + PROMASEAL® A	-/60/60	FAS190202 R4.4
Up to 50mm copper	Single Layer of PROMASEAL® Bulkhead Batt + PROMASEAL® A + 400mm PROMASEAL® SupaWrap	-/60/60	FAS190202 R4.4
A - Up to 40mm Conduit	Refer to FCO 2458	-/60/60	FCO-2458
B - Small Electrical/power cables/fiber	Refer to FCO 2458	-/60/60	FCO-2458
C - Lagged copper pair coils	Refer to FCO 2458	-/60/60	FCO-2458
D - Lagged copper	Refer to FCO 2458	-/60/60	FCO-2458
E- Large Electrical Cables	Refer to FCO 2458	-/60/60	FCO-2458
F - Combination electrical cables	Refer to FCO 2458	-/60/60	FCO-2458
Combinations of cables, lagged pipes, including conduits (A-F)	Refer to FCO 2458	-/60/60	FCO-2458

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

The following services have been tested/approved in accordance with:

AS1530.4:2014 & AS4072.1:2005

protecting penetrations through 60min fire rated lightweight partitions.

**Service penetrations in a minimum 118mm thick wall using minimum 92mm steel stud clad with minimum 13mm Fire Rated Plasterboard each face**

Service	Protection	FRL	Approval No
50mm Copper pipe lagged with Thermobreak	PROMASEAL® SupaWrap 40 through the wall & PROMASEAL® A Acrylic Sealant	-/60/60	A-17-036A
32mm Copper pipe lagged with Thermobreak	PROMASEAL® SupaWrap 40 through the wall & PROMASEAL® A Acrylic Sealant	-/60/60	A-17-036A
19mm Copper pipe lagged with Thermobreak	PROMASEAL® SupaWrap 40 through the wall & PROMASEAL® A Acrylic Sealant	-/60/60	A-17-036A
16mm Copper pipe lagged with Thermobreak	PROMASEAL® SupaWrap 40 through the wall & PROMASEAL® A Acrylic Sealant	-/60/60	A-17-036A
Metal tap spindle with breech	PROMASEAL® AG Intumescent Sealant	-/60/60	A-19-002
PROMASEAL® Bulkhead Batts (Max 550x450mm Opening)	Face mounted and fixed to each side of the wall	-/60/60	FAS190202
Various Services through the Above	Refer FAS190202	-/60/60	FAS190202

- Results for timber frame not applicable to steel unless specifically assessed and vice versa
- Results can be applied to masonry or concrete walls of equal or greater thickness
- Results can be applied to systems with larger studs and thicker facing boards

\* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628) Email: [PAPL.Mail@etexgroup.com](mailto:PAPL.Mail@etexgroup.com) Visit: <http://www.promat.com>

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

The following services have been tested/approved in accordance with:

AS1530.4:2014 & AS4072.1:2005

protecting penetrations through 60min fire rated lightweight partitions.

**Service penetrations in a minimum 116mm thick wall using minimum 90mm timber stud clad with minimum 13mm Fire Rated Plasterboard each face.**

Service	Protection	FRL	Approval No
40-100mm uPVC pipe	PROMASTOP® UniCollar®	-/60/60	Holmes 148209
150mm uPVC pipe	PROMASTOP® UniCollar® (+13mm thickening to both faces)	-/60/60	Holmes 148209
25mm uPVC flexible conduit with cables	PROMASEAL® Conduit Collar	-/60/60	FP 6114
Single 2.5mm 2C+E TPS Cable	PROMASEAL® A Acrylic Sealant	-/60/60	FP 6114
5 x 2.5mm 2C+E TPS Cables	PROMASEAL® A Acrylic Sealant	-/60/60	FP 6115
9 x CAT Data Cable Bundle	PROMASEAL® A Acrylic Sealant	-/60/60	FP 6114
16mm PEX pipe	PROMASEAL® AG Intumescent Sealant	-/60/60	FP 6115
20mm PEX pipe	PROMASEAL® AG Intumescent Sealant	-/60/60	FP 6115
20mm PP-R pipe	PROMASEAL® Conduit Collar	-/60/60	FP 6114
6.35mm/12.70mm pair coil and a single 2.5mm 2C+E TPS Cable	PROMASEAL® FC50 with PROMASEAL® Grafitex Paste	-/60/60	FP 6114
3 x 19mm Armaflex lagged copper pipes in trefoil configuration	PROMASTOP® UniCollar® & PROMASEAL® Graf 4T	-/60/60	FP 6114
Single 50mm Copper pipe with 25mm Armaflex Insulation	PROMASEAL® FlexiWrap	-/60/60	FP 6114
50mm Copper pipe (no wrap)	PROMASEAL® A Acrylic Sealant	-/60/-	FP 6114
50mm Copper pipe (wrap)	PROMASEAL® SupaWrap 40 & PROMASEAL® A Acrylic Sealant	-/60/60	FP 6115
PROMASEAL® Bulkhead Batts (Max 550x450mm Opening)	Face mounted and fixed to each side of the wall	-/60/60	FP 6115
Various Services through the Above	Refer FAS190202	-/60/60	FAS190202